

Q&A Transcript for Modeling Utility-scale Photovoltaic Projects in SAM Webinar

September 20, 2023

"charge from system" means charge from grid or charge from solar?

For the PV-Battery configuration, yes. Another configuration is Generic Battery, which Brian is

Since this is a BTM application, would the target kW be based on what is in the best interest of the customer/rate-payer? For example, a demand-charge kW value?

Yes, SAM chooses a grid power target is chosen to reduce grid purchases from the grid from the e

Why would "system energy forecast" be info necessary to a BTM customer?

The "system energy forecast" is a forecast of the power the customer's PV system will generate.

Do TOU options include on-peak, off-peak and partial peak options?

Yes, you can define up to 6 TOU periods for battery dispatch to represent peak, off-peak, and pa